



- WINDOW, SEE DRAWINGS BY OTHERS
- DUPONT™ FLEXWRAP™ NF SILL FLASHING BEYOND
- DUPONT™ RESIDENTIAL SEALANT OR RECOMMENDED SEALANT
- DUPONT™ FLEXWRAP™ NF, EXTEND MIN. 6" UP BOTH JAMBS AND MIN. 2" ONTO FACE OF RECESSED WINDOW FRAME. USE 6" WIDE FOR 2x4 AND 9" WIDE FOR 2x6 FRAMING.
- BUILT-IN STUCCO KEY
- SET FLANGE IN SEALANT, EXCEPT FOR MIN. TWO (2), 2" GAPS FOR EVERY 4' OF WINDOW
- DUPONT™ FLEXWRAP™ NF CORNER BEYOND
- DUPONT™ FLEXWRAP™ NF CORNER, TO EXTEND MIN. 2" ONTO FACE OF RECESSED WINDOW FRAME AND 2" ONTO FACE OF OUTSIDE WALL.
- CONTINUOUS SLOPED BLOCKING (2% MIN.)
- METAL LATH
- 9" DUPONT™ FLASHING TAPE, LAPPING ONTO DUPONT™ TYVEK® WRB
- INTERVENING LAYER
- DUPONT™ TYVEK® WRB
- SHEATHING, SEE DRAWINGS BY OTHERS
- STRUCTURE, SEE DRAWINGS BY OTHERS

NOTES:

1. DETAIL IS FOR RECESSES UP TO 4". SEE SEQUENCING SHEETS FOR ADDITIONAL INSTALLATION GUIDANCE.
2. DETAIL FOR BUILDINGS LESS THAN 5 STORIES AND LOW-RISE MULTI-FAMILY RESIDENTIAL BUILDINGS LESS THAN 6 STORIES WHEN PERFORMANCE REQUIREMENTS DO NOT EXCEED ASTM E1677 (65 MPH EQUIVALENT STRUCTURAL LOAD AND 15 MPH EQUIVALENT WIND-DRIVEN RAIN WATER INFILTRATION), AND WINDOW/DOOR DESIGN RATINGS THAT DO NOT EXCEED DP45.
3. INTERVENING LAYER CAN BE SECOND LAYER OF DUPONT™ TYVEK® WRB, A LAYER OF GRADE D BUILDING PAPER, FELT, RIGID FOAM BOARD OR THE BACKING OF PAPER-BACKED LATH.
4. REPAIR MINOR HOLES WITH DUPONT™ TYVEK® TAPE.
5. FASTEN DUPONT™ TYVEK® WRB WITH APPROVED FASTENERS AND SPACING.
6. INTERIOR VAPOR RETARDER MAY BE REQUIRED IN SOME REGIONS.
7. LOCAL LAWS, ZONING, AND BUILDING CODES VARY AND THEREFORE GOVERN OVER MATERIAL SELECTION AND DETAILING SHOWN.
8. FOR ADDITIONAL INFORMATION REGARDING PRODUCT INSTALLATION, REFER TO THE APPLICABLE DUPONT™ INSTALLATION GUIDELINE.

SCALE: NOT TO SCALE
 REVISION DATE: 11/1/16
 DRAWING: R-CP-2153-MA

INTEGRAL FLANGED WINDOW RECESSED UP TO 4" - SILL
 CEMENT PLASTER

