



Municipal



DuPont™ UF SFD-2880: DuPont's Ultrafiltration Solutions Produce Drinking Water to 25,000 People in Croatia

The challenge

Stara Strojarna Ultrafiltration plant is located in Petrinja, Croatia. The plant was started up in April 2015 and it is working at constant production capacity of 7,776 m³/day of filtrate water. This installation is fed with water from 5 different wells, and the water product is collected in a reservoir that reaches the potable water distribution network providing drinking water to the surrounding community of 25,000 people.

The solution

The feed water entering the UF system has turbidity values ranging from 8 to 120 NTU, depending on the season. The well water is pretreated through a 200 µm self-cleaning filter prior to the Ultrafiltration system. The plant configuration consists of 3 lines in operation. Each line is designed with 20 DuPont™ UF SFD-2880 modules, operating at a flux of 70 LMH (L/m²/h). When one of the lines enters in backwash or chemical cleaning mode, the other two lines are able to absorb the increase in flux up to 105 LMH to maintain the total water production constant.

Regarding the cleaning strategy, the continuous dosage of NaOCl in the filtrate water and during BWs is enough to maintain a sustainable operation during most of the time. Only during periods of bad weather when turbidity values are higher, additional BW cleanings with 0.8 mg/L of NaOCl are conducted every 10 standard BW cycles for 3 minutes, to remove the organic fouling accumulated on the UF fibers and guarantee the production of potable water for the community. In addition, only 1 Chemical Enhanced Backwash (CEB) is performed every 6 months.

The produced water is continuously disinfected with 0.3 ppm of Sodium Hypochlorite (NaOCl), which is added to the filtrate line before the Product Reservoir so that the product water is ready to be directed to the distribution network. Figure 1 shows a schematic diagram of the water filtration process. The filtrate water used for Backwashes (BW) also contains NaOCl, which is generated in-situ. The addition of NaOCl during BWs enhances the cleaning efficiency and helps to reduce membrane fouling, ultimately leading to a more stable operation.

Fast Facts

Location: Petrinja, Croatia

OEM: Tehnobiuro d.o.o.
Maribor Slovenia

Market segment / Application:
Municipal, Drinking Water

DuPont products used:
60 DuPont™ UF SFD-2880
modules, 20 modules per line

Feed Water Source: Well water

Start-up Date: April 2015

The benefits

After one year in operation the Trans Membrane Pressure (TMP) stays at 0.7 – 0.9 bar at 70 LMH and 0.9 – 1.5 bar at 105 LMH, same values as in the startup, and no Cleaning-In-Place (CIP) has been carried out so far. Product water quality has been consistent during operation, with turbidity values below 0.1 NTU and free of bacteriological contamination. Figure 2 shows actual turbidity measurements of the feed and the product water after the Ultrafiltration system.

DuPont Ultrafiltration membranes act as a barrier for fine particles, suspended solids, colloidal matter, microorganisms and low molecular weight species without modifying the salinity of the final potable water. Stara Strojarna Ultrafiltration plant is an example where DuPont Ultrafiltration brings innovative drinking water solutions to the community.




Figure 1: Schematic diagram of Petrinja Ultrafiltration water treatment plant.




Figure 2: Left. Filtrate and feed UF water. Middle. Turbidity of filtrate (top) and feed water (bottom). Right. Petrinja UF installation.



Water Solutions
Have a question? Contact us at:
[dupont.com/water/contact-us](https://www.dupont.com/water/contact-us)

The descriptions, designs, data and product information contained herein are presented in good faith and are based on inge GmbH's current knowledge and experience. inge GmbH cannot accept any liability for the accuracy of this product information, which is provided at no charge and for guidance only.

inge® products are designed to be operated in accordance with the corresponding inge® product documentation. The product information and products are protected by copyright and/or other intellectual property laws worldwide. However, inge GmbH cannot guarantee that the product information and products can be used without infringing third party intellectual property rights. The products and product information may only be used, distributed and marketed with the express prior permission of inge GmbH.

No warranties of any kind regarding the products, either expressed or implied, including, but not limited to, warranties of merchantability, fitness for a particular purpose or no third party rights are made, other than as expressly set out in the contractual agreement with the customer. Mechanical stability and full functionality of inge® products can only be provided by genuine inge® parts.

inge GmbH reserves the right to modify products and product information at any time without prior information. Current product information can be obtained from the website <https://www.dupont.com/brands/inge.html>.

DuPont™, the DuPont Oval Logo, and all trademarks and service marks denoted with ™, SM or ® are owned by affiliates of DuPont de Nemours, Inc. unless otherwise noted. © 2021 DuPont.

Form No. 45-D01780-en CDP, Rev. 3
March 2021